



NOTES:

1. ALL PIPE STAKES, HARDWARE AND MATERIALS SHALL BE HOT DIPPED GALVANIZED AFTER FABRICATION.



City of  
Bellevue

STORM AND SURFACE  
WATER UTILITY

TITLE

PIPE STAKE ANCHOR ASSEMBLY

JANUARY 2013

NO SCALE

NO. D-57